

Town of Grafton
Wastewater Treatment Facility

Vincent Drago

Chief Operator

9 Depot Street

South Grafton, MA 01560

Phone: (508) 839.8526 Fax: (508) 839.8523

E-Mail: dragov@grafton-ma.gov

Memo

To: Planning Board

From: Vincent Drago

Date: May 28, 2015

Re: Grist Mill Village

Please see the attached memo which was provided to the engineer.

Town of Grafton

Wastewater Treatment Facility

Vincent Drago

Chief Operator

9 Depot Street

South Grafton, MA 01560

Phone: (508) 839.8526

Fax: (508) 839.8523

E-Mail: dragov@grafton-ma.gov

Memo

To: John Grenier

From: Vincent Drago

Date: May 28, 2015

Re: Grist Mill Village

Please address these issues :

A six inch service stub must be provided to the property line for house numbers 94,95,96,97,99 and 101 Pleasant St.

The existing sewer manhole # 01685 on Gristmill Rd. extends east approximately 75 feet towards Pleasant St. with no manhole indicating the end.

An additional check list for sewer construction plans is included.

The Town of Grafton sewer department testing standards must be shown on plan (attached).