



Natalia Alward <alwardn@grafton-ma.gov>

109 Creeper Hill Rd. - Feedback Earth, Inc. - Modification of Special Permit/SPA

1 message

koshivosk@grafton-ma.gov via Town of Grafton MA <cmsmailer@civicplus.com>
Reply-To: "koshivosk@grafton-ma.gov" <cmsmailer@civicplus.com>
To: Planning Department <planningdept@grafton-ma.gov>

Fri, May 7, 2021 at 2:25 PM

Planning Board Public Comment Form
Submitted from the Town of Grafton website on Friday, May 7, 2021 - 2:25pm

Submitted on Friday, May 7, 2021 - 2:25pm
Submitted by user: Anonymous
Submitted values are:

Select a Project: [109 Creeper Hill Rd. - Feedback Earth, Inc. - Modification of Special Permit/SPA](#)
First Name: ZBA
Last Name: ZBA
Email Address: koshivosk@grafton-ma.gov
Street Address: [30 Providence Road](#)
City: Grafton
State: Massachusetts

Public Comment Disclaimer: I have read and understand the Public Comment Disclaimer.
Comments: The concrete pad will need to meet is front setback. Currently from the proposed plans, the corner is only 23' off the front setback and in the OLI district the setback needs to be 40'. This will need to come before the ZBA for a variance/special permit.