



**GRAFTON**  
Massachusetts

Natalia Alward <alwardn@grafton-ma.gov>

---

**Re: Request for Comments: SP 2021-04/SPA, Accessory Apt., 23 N. Brigham Hill Road, Compton**

---

**Michael Killeen** <killeenm@grafton-ma.gov>  
To: Natalia Alward <alwardn@grafton-ma.gov>

Mon, Jun 7, 2021 at 7:37 AM

Good morning,

The fire department has no questions on the in-law addition, only a comment. The contractors must be aware that adding an additional bedroom changes the code, and therefore the entire house must meet current smoke and carbon monoxide detector standards and regulations.

Thank you.

Respectfully,

Captain Michael Killeen  
Fire Prevention Officer  
Grafton Fire Department