



**GRAFTON**  
Massachusetts

Natalia Alward <alwardn@grafton-ma.gov>

---

**Re: Request for Comments: SPA 2008-1.1, Modification to Site Plan Approval, 84-94 Creeper Hill Road**

1 message

---

**Michael Killeen** <killeenm@grafton-ma.gov>  
To: Natalia Alward <alwardn@grafton-ma.gov>

Mon, Jun 7, 2021 at 7:33 AM

Good morning,

The fire department has the following questions / comments at this stage.

- What is the new square footage of the footprint of the building with the additional structures that are to be built?
- What is the added value of the addition versus the current structure?
- There is a suppression system needed for the paint booth, which I believe they are aware of and will submit plans for.

Thank you.

Respectfully,

Captain Michael Killeen  
Fire Prevention Officer  
Grafton Fire Department