



Natalia Alward <alwardn@grafton-ma.gov>

Re: Request for Comments: SP 2002-11.2 / SPA, 86 Main Street, AT&T

1 message

Michael Killeen <killeenm@grafton-ma.gov>
To: Natalia Alward <alwardn@grafton-ma.gov>

Tue, Oct 19, 2021 at 1:44 PM

Good afternoon,

If this generator is next to a driveway or parking lot, it should be protected from any potential moving vehicle, with the use of bollards. Thank you.

Respectfully,

Captain Michael Killeen
Fire Prevention Officer
Grafton Fire Department