



Request for Comments - 61 Leland Street

Nancy Connors <connorsn@grafton-ma.gov>
To: Jan Elyse Taylor <taylorj@grafton-ma.gov>

Thu, Jan 26, 2023 at 2:43 PM

Hello

The proposed paddock, driveway & garage must maintain a 100 foot distance to all wells, 10 foot distance to septic tank and 20 foot distance to the leach field. Thank you.

Nancy Connors
Office Manager
Health Department
[30 Providence Road](#)
[Grafton, MA 01519](#)
Phone: 508-839-5335 X1580
Fax: 508-839-8559

connorsn@grafton-ma.gov

www.grafton-ma.gov

Follow Us: [Facebook](#) | [Twitter](#)

When responding, please remember the Secretary of State considers e-mail a public record.

Consider the environment before printing this e-mail.

On Thu, Jan 26, 2023 at 9:43 AM Jan Elyse Taylor <taylorj@grafton-ma.gov> wrote:

[Quoted text hidden]