



Natalia Alward <alwardn@grafton-ma.gov>

Request for Comments: SP 2023-01 / SPA; 18 & 22 Donahue Lane

Nancy Connors <connorsn@grafton-ma.gov>
To: Planning Department <planningdept@grafton-ma.gov>

Thu, Feb 9, 2023 at 9:01 AM

Septic system and reserve area are not to be built on and H-20 loading is to be used in areas where there will be vehicle traffic.

Thank you.....

Nancy Connors
Office Manager
Health Department
30 Providence Road
Grafton, MA 01519
Phone: 508-839-5335 X1580
Fax: 508-839-8559

connorsn@grafton-ma.gov

www.grafton-ma.gov

Follow Us: [Facebook](#) | [Twitter](#)

When responding, please remember the Secretary of State considers e-mail a public record.

 **Consider the environment before printing this e-mail.**